CERTIFICATE



Certificate of Conformity with Technical Requirements In: API STD 607 Seventh Edition, June 2016/ISO 10497:2010

Fire Test for Quarter-turn Valves and Valve Equipped with Nonmetallic Seats

Certificate No.: 269804

Ref. Test report No.: P-269804

Name of Applicant: ERIKS Flow Control.

Address: Cypresbaan 63 2908 LT Capelle aan den IJssel, The Netherlands.,

We hereby certify that the fire test on below valves have been conducted for above mentioned manufacturer and witnessed by TÜV SÜD Engineer according to requirements of API Std 607 Seventh Edition, June 2016 and ISO 10497: 2010. The testing results of valves meet the requirements of API Std 607 Seventh Edition, June 2016 and ISO 10497: 2010.

1.Description of Test Valve*:

| Type (Fig. No.) of Test Valve | 7245 | 7285 | 7245 | |
|--------------------------------|------------------------------|----------------|---------------|--|
| Description of Test Valve * | 2pcs Flanged End Ball Valves | | | |
| Valve Size, NPS | 2 | 2 | 4 | |
| Pressure Rating (ANSI Class) | 150 | | | |
| Valve Body Material | ASTM A216 WCB | ASTM A351 CF8M | ASTM A216 WCB | |
| Weight of Test Valve(Kgs) | 7.49 | 8.2 | 29 | |
| Drawing No. /Rev. | D36538 Rev. 2 | D36541 Rev. 2 | D36538 Rev. 2 | |

2. Qualified Range of Valves:

| Туре | 7245, 7249, 7257, 7285, 7289, 7297, 72451, 72491, 72571, 72851, 72891, | | |
|----------------------------|--|--|--|
| (Fig No.) | 72971, 7248, 7288, 72481, 72881 | | |
| Description of Valves | 2pcs Flanged End Ball Valves | | |
| Qualified Pressure Ratings | Class 150, class 300 or PN10, PN16, PN25, PN40 | | |
| Qualified Sizes | NPS2 and below; 2-1/2; 3; 4; 5; 6; 8; or DN50 and below; 65; 80; 100; 125; | | |
| | 150; 200 | | |
| Qualified Valve Material | Ferritic and Austenitic steel | | |
| Qualified Valves Mass | 5.62 kgs and larger | | |
| Ref, Drawing No./ Rev. | D36538 Rev. 2; D36539 Rev. 2; D36540 Rev. 2; | | |
| | D36541 Rev. 2; D36542 Rev. 2; D36543 Rev. 2 | | |

This certificate is issued according to API Std 607 Seventh Edition, June 2010 and ISO 10497: 2010 based upon the test report for above mentioned test valves.

The additional valve qualification shall be limited to similar valves of same basic design (including calculation method) and construction as the test valves and of the same nonmetallic materials as the test valve in the seat-to-closure member seal, seat-to-body seal, stem seal, and body joint and seal, etc., filled PTFE and non-filled PTFE. according to API Std 607 Seventh Edition, June 2016 and ISO 10497: 2010.

Beijing/ JUL 20th, 2020

(Place, date)

Mr. Bingjiang LIU
TÜV SÜD Industrie Service GmbH
Beijing office

Tel.: +86 10 65906186

Fax: +86 10 65906182

Certificate No.: 269804

Ref. Test report No.: P-269804

Name of Manufacturer: ERIKS Flow Control.

Address:

Cypresbaan 63 2908 LT Capelle aan den IJssei, The Netherlands



Technical Data of Test Valves

1. Valve Type: 2 PCS Flanged End Ball Valves

2. Description of Test Valve:

| Type of Test Valves | 7245 | 7285 | 7245 | |
|-----------------------------|-------------------------------|-------------|-------------|--|
| Description of Valves | 2 PCS Flanged End Ball Valves | | | |
| Pressure Class | 150 | | | |
| Valve Size, NPS | 2 | 2 | 4 | |
| Test Valve SN. | 12/14.05001 | 12/14.05002 | 12/14.05006 | |
| Flanged End Standard | ASME B16.5: E2017 | | | |
| Face to Face Standard | ASME B16.10: E2017 | | | |
| nspection and Test Standard | API 598: E2016 | | | |

3. Detail of Test Valve:

| Part Name | Material | | |
|------------------------------|----------------------|----------------------|----------------------|
| Body | ASTM A216WCB | ASTM A351 CF8M | ASTM A216 WCB |
| Body End | ASTM A216WCB | ASTM A351 CF8M | ASTM A216 WCB |
| Ball | ASTM A351 CF8M | ASTM A351 CF8M | ASTM A351 CF8M |
| Seat Ring | PTFE (TFM1600) | PTFE (TFM1600) | PTFE (TFM1600) |
| Stud | ASTM A193 B7 | ASTM A193 B8 | ASTM A193 B7 |
| Stem | ASTM A276 316 | ASTM A276 316 | ASTM A276 316 |
| Antistatic Device | AISI 304 | AISI 316 | AISI 304 |
| Thrust Washer | PTFE | PTFE | PTFE |
| O-Ring | Elastomer | Elastomer | Elastomer |
| Stem Seal | Graphite | Graphite | Graphite |
| Bush | AISI 304 | AISI 304 | AISI 304 |
| Gasket | SPW316+PTFE+Graphite | SPW316+PTFE+Graphite | SPW316+PTFE+Graphite |
| Gland | AISI 304 | AISI 304 | AISI 304 |
| Stem Nut | ASTM A194 8 | ASTM A194 8 | ASTM A194 8 |
| Gland Bolting | A2-70 | A2-70 | A2-70 |
| Belleville Washer | AISI 301 | AISI 301 | AISI 301 |
| Body Nut | ASTM A194 2H | ASTM A194 8 | ASTM A194 2H |
| Weight of Test Valve(Kgs) | 7.49 | 8.2 | 29 |
| Design Drawing No.: | D36538 ReV. 2 | D36541 ReV. 2 | D36538 ReV. 2 |

Beijing/ JUL 20th, 2020

(Place, date)

Mr. Bingjiang LID TÜV SÜD Industrie Service GmbH

TÜV SUD Industrie Service GmbH Beijing Office
M Building, No. 7 Wangjing Zhonghuan Nanlu, Chaoyang District
Beijing 100102, P. R. China Tel.: +86 10 65906186

Fax: +86 10 65906182