

Number	K 6149/02	Replaces	K 6149/01
Issued	2002-04-01	Dated	1996-04-01

Product Certificate


Non return valves for water

Based on pre-certification tests as well as periodic inspections by Kiwa, the products referred to in this certificate and marked with the Kiwa-mark as indicated under 'Marking', manufactured by

VAG Armaturen GmbH

may, on delivery, be relied upon to comply with the Kiwa evaluation guideline BRL-K651 "Non return valves for water in nominal sizes up to and including to 1200 mm, Class B".

Kiwa N.V.



Ing. B. Meekma
Director,
Certification and Inspection

This certificate is issued in accordance with the Kiwa-Regulations for Product Certification and consists of 3 pages.

Publication of the certificate is allowed.

*) This is a translation. Only the Dutch text is legally binding.

Kiwa N.V.
Certification and Inspection
Sir W. Churchill-laan 273
Postbus 70
2280 AB Rijswijk
The Netherlands

Telephone +31 70 41 44 400
Telefax +31 70 41 44 420

Manufacturer

VAG Armaturen GmbH
Carl-Reutherstraße 1
63805 MANNHEIM
Duitsland
Phone +49 621749-0
Fax +49 6217491710
Website www.vag-armaturen.com
e-mail info@vag-armaturen.com

Page

2

Number

K 6149/02

Replaces

K 6149/01

Issued

2002-04-01

Dated

1996-04-15

Non return valves for water

PRODUCT SPECIFICATION

KIPP (SKR) non return valves

DN	200
DN	250
DN	300
DN	350
DN	400
DN	450
DN	500
DN	600
DN	700
DN	800
DN	900
DN	1000
DN	1200

Page	3	Number	K 6149/02	Replaces	K 6149/01
		Issued	2002-04-01	Dated	1996-04-15

Non return valves for water

APPLICATION AND USE

Non return valves for water are to be applied in drinking water systems with a working pressure of maximum 1000 kPa and a maximum water temperature of 30°C.

MARKING

The products are marked with the Kiwa-mark.

Place of the mark:

On the body

Compulsory specifications:

- Manufacturers Name or mark
- Nominal size (DN) on the body
- Nominal pressure (PN) on the body
- Direction of flow on the body

Remark

- The compulsory specifications may also be applied to the identification plate
- The identification plate must be bear at minimum the Kiwa mark and the manufacturers mark

Method of marking:

- Non-erasable;
 - Visible when mounting.
-

RECOMMENDATIONS FOR CUSTOMERS:

- | | |
|--|--|
| <ol style="list-style-type: none"> 1. Check at the time of delivery whether: <ol style="list-style-type: none"> 1.1 the producer has delivery in accordance with the agreement; 1.2 the mark and the marking method are correct; 1.3 the products show no visible defects as a result of transport etc. 2. If you should reject a product on the basis of the above, please contact: <ol style="list-style-type: none"> 2.1 VAG Armaturen GmbH
and, if necessary, 2.2 Kiwa N.V. | <ol style="list-style-type: none"> 3. Consult the producer's processing guidelines for the proper storage and transport methods. 4. Check whether this certificate is still valid by consulting the Kiwa website www.kiwa.nl. |
|--|--|
-